

TO: Those Contractors who attended mandatory pre-bid conference

## **ADDENDUM #2**

**October 19, 2016**

**Valencia County  
Judicial Complex  
HVAC Controls Renovation  
IFB #VCB-FY17-005  
Valencia County Purchasing Department  
Michelle Romero  
michelle.romero@co.valencia.nm.us  
444 Luna Ave., Suite 100A  
Los Lunas, NM 87031**

The following items shall be incorporated into the Contract Documents.

All other provisions of the Contract Documents shall remain unchanged. This addendum is hereby made part of the Contract Documents to the same extent as though it were originally included therein. Each bidder shall acknowledge receipt of this addendum on the Bid Proposal Form in the space provided.

Question number 28 from Addendum and Q&A #1 has been clarified below.

Question 28 read:

28. Sheets M-1, 2, and 3 keynote 14 state “install fire smoke damper and smoke damper monitor per sequence of operation.” There isn’t a fire smoke damper or monitor listed in the sequence of operation. Could we find out exactly what we are being asked to provide for this note?

~~**ANSWER:** Smoke Dampers to send out alarm if they close.~~

**AMENDED ANSWER:** Contractor is responsible to provide an alarm though auxiliary input from existing smoke dampers to detect if dampers close.